



**NOTES:**

1. CUT-IN GATE VALVE SHOULD BE FULL BODY DUCTILE IRON.
2. ANCHOR BLOCKING PER AUD 1.13 DETAIL.
3. CONTRACTOR TO FIELD VERIFY EXISTING PIPE MATERIAL AND O.D.
4. VALVES SHALL OPEN LEFT, BLACK NUT, IF INSTALLED SOUTH OF GORDON HWY. AND OPEN RIGHT, RED NUT, IF INSTALLED NORTH OF GORDON HWY.
5. GATE VALVES SHALL BE NON-RISING STEM TYPE WITH RESILIENT SEATED GATE VALVE UNLESS OTHERWISE SPECIFIED. VALVES SHALL OPEN LEFT, BLACK NUT, IF INSTALLED SOUTH OF GORDON HWY AND OPEN RIGHT, RED NUT, IF INSTALLED NORTH OF GORDON HWY.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

**APPROVED JAN. 2021**

REVISED: JANUARY 2021

**CUT-IN GATE VALVE OR TEE**

**AUD DETAIL 1.5**

**AUGUSTA UTILITIES DEPARTMENT  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901**

