



PROFILE VIEW

NOTES:

1. WATER METERS SHALL BE PURCHASED FROM AUGUSTA UTILITIES DEPARTMENT.
2. WATER METERS SHALL BE INSTALLED BY CONTRACTOR.
3. OVERSIZED METER BOXES ARE TO BE ROME (16"x22"x16") CAST IRON OR APPROVED EQUAL.
4. METER BOXES SHALL BE INSTALLED AND MAINTAINED BY THE DEVELOPER OR CONTRACTOR UNTIL THE RESIDENCE IS OCCUPIED.
5. NEW MAIN & SERVICES SHALL HAVE A MINIMUM OF 48" COVER UNLESS EXISTING MAIN DOES NOT ALLOW.
6. 12 GAUGE SINGLE STRAND COATED WIRE TO BE LOCATED ON TOP OF WATER MAIN.
7. APPROVED ADAPTERS SHALL BE USED WHERE NECESSARY TO PROVIDE A TRANSITION BETWEEN PIPES AND/OR FITTINGS OF DIFFERING OUTSIDE DIAMETERS AND MATERIALS.
8. METER SHOULD BE LOCATED 1 FOOT INSIDE OF RIGHT OF WAY.
9. SEE AUD DETAIL 1.17 FOR VALVE BOX INSTALLATION DETAIL.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

APPROVED JAN. 2020

REVISED: APRIL 2019

2" WATER SERVICE

AUD DETAIL 1.11

**AUGUSTA UTILITIES DEPARTMENT
452 WALKER STREET, SUITE 200
AUGUSTA, GA 30901**

