



**NOTE:**

1. INSTALL AS CLOSE TO BUILDING AS POSSIBLE.
2. INSTALL IN AN AREA NOT PRONE TO DAMAGE (FLOWER BED, ETC.).
3. INSTALL POP-OFF VALVE AND CLEAN OUT APPROXIMATELY 1 INCH ABOVE GRADE.
4. ALL PIPE DIAMETERS ARE 6 INCHES.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

**APPROVED JAN. 2020**

REVISED: JANUARY 2018

**BACKWATER VALVE**

**AUGUSTA UTILITIES DEPARTMENT  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901**

**AUD DETAIL 2.9**

