



PROFILE VIEW

NOTES:

1. CUT & REMOVE EXISTING PIPE.
2. REPLACE CONFLICT SECTION WITH A MINIMUM OF 10 L.F. OF DUCTILE IRON PIPE (6" - 16": CLASS 350, 18"+: CLASS 300).
3. PLACE SMITH-BLAIR COUPLINGS OR APPROVED EQUAL ON EITHER SIDE OF PIPE SECTION WHERE D.I.P. CONNECTS TO EXISTING PIPE. (2 NEEDED)
4. IF EXISTING LOCATING WIRE IS PRESENT, REATTACH WITH NEW WIRE AT BOTH ENDS.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

APPROVED JAN. 2020

REVISED: APRIL 2019

**PROPOSED SEWER CROSSING EXISTING
WATER MAIN**

AUD DETAIL 2.10

**AUGUSTA UTILITIES DEPARTMENT
452 WALKER STREET, SUITE 200
AUGUSTA, GA 30901**

