



NOTE:  
STREET RATED SEWER CLEANOUT CAP REQUIRED WHEN LOCATED IN PAVEMENT.  
THERE WILL BE NO BENDS BETWEEN THE SEWER CLEANOUT AND THE SEWER TAP

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

**APPROVED JAN. 2021**

REVISED: JANUARY 2021

**SANITARY SEWER CLEANOUT**

**AUD DETAIL 2.9**

**AUGUSTA UTILITIES DEPARTMENT**  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901

