



PROFILE VIEW

NOTES:

1. CUT & REMOVE EXISTING PIPE.
2. REPLACE CONFLICT SECTION WITH A MINIMUM OF 10 L.F. OF DUCTILE IRON PIPE (6" - 16": CLASS 350, 18"+: CLASS 300).
3. PLACE SMITH-BLAIR COUPLINGS OR APPROVED EQUAL ON EITHER SIDE OF PIPE SECTION WHERE D.I.P. CONNECTS TO EXISTING PIPE. (2 NEEDED)
4. IF EXISTING LOCATING WIRE IS PRESENT, REATTACH WITH NEW WIRE AT BOTH ENDS.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

**APPROVED JAN. 2021**

REVISED: JANUARY 2021

**PROPOSED SEWER CROSSING EXISTING  
WATER MAIN**

**AUD DETAIL 2.11**

**AUGUSTA UTILITIES DEPARTMENT  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901**

