

CAUTION BURIED WATER LINE BELOW

CAUTION BURIED SEWER LINE BELOW

CAUTION BURIED FIBER OPTIC LINE BELOW

NOTES:

1. UNDERGROUND MARKING TAPE SHALL BE (4" WIDTH), MARKING TAPE, WITH A MINIMUM 4.0 MIL OVER-ALL THICKNESS.
2. TAPE MUST MEET THE APWA COLOR-CODE STANDARD FOR IDENTIFICATION OF BURIED UTILITIES (WATER - BLUE, SEWER - GREEN, FIBER OPTIC - ORANGE).
3. TAPE TO BE INSTALLED 2' ABOVE THE WATER LINE.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

**APPROVED JAN. 2021**

REVISED: JANUARY 2021

**DETECTOR TAPE**

**AUD DETAIL 3.6**

**AUGUSTA UTILITIES DEPARTMENT  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901**

