


PROFILE VIEW

NOTES:

1. EACH VALVE BOX SHALL BE SLIP-TYPE TO ADJUST FOR A MINIMUM COVER OF 36 INCHES.
2. AN AUD INSPECTOR SHALL BE PRESENT DURING TESTING.
3. ALL TESTING SHALL BE IN ACCORDANCE WITH AUD STANDARDS AND SPECIFICATIONS.
4. VALVES SHALL OPEN LEFT, BLACK NUT, IF INSTALLED SOUTH OF GORDON HWY AND OPEN RIGHT, RED NUT, IF INSTALLED NORTH OF GORDON HWY.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

REVISED: JANUARY 2018

BUTTERFLY VALVE ASSEMBLY	AUGUSTA UTILITIES DEPARTMENT 452 WALKER STREET, SUITE 200 AUGUSTA, GA 30901	
AUD DETAIL 1.5		