



PROFILE VIEW

NOTES:

1. DISTANCE BETWEEN THE VALVE AND STRAINER ON INLET SIDE AND BETWEEN THE METER AND VALVE ON DISCHARGE SIDE SHALL BE 5X DIAMETER OF PIPE.
2. SEE DETAILS 5.6 & 5.7.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

REVISED: JANUARY 2018

**WATER METER  
ABOVE GROUND ENCLOSURE**

**AUD DETAIL 1.20.2**

**AUGUSTA UTILITIES DEPARTMENT  
452 WALKER STREET, SUITE 200  
AUGUSTA, GA 30901**

