



NOTES:

1. IF MANHOLE DEPTH EXCEEDS 20 VERTICAL FEET WALL THICKNESS SHALL BE 6 INCHES.
2. CURVATURE OF INVERT TO HAVE LARGEST POSSIBLE RADIUS.
3. MANHOLE STEPS SHALL BE PLACED 1'-0" O.C. MAXIMUM. (REFERENCE AUD DETAIL 3.5)
4. ALL MANHOLE SECTIONS TO HAVE EXTERIOR JOINTS WRAPPED.
5. WHEN MANHOLE IS OFF SITE INTEGRATED RING AND COVER SHALL BE REQUIRED, AND A MINIMUM 2' ABOVE GRADE. (REFERENCE AUD DETAIL 2.7.1 AND 2.7.2)
6. DOGHOUSE - BREAKOUT PRECAST OPENING TO FIT OVER PIPE.
7. NO MORE THAN 6" ADJUSTMENT BY RISERS ON RING AND COVER.

NO REVISION OR MODIFICATION OF THIS DETAIL SHALL BE MADE WITHOUT PRIOR WRITTEN APPROVAL FROM AUGUSTA UTILITIES DEPARTMENT.

REVISED: JANUARY 2018

PRECAST MANHOLE

AUD DETAIL 2.3

AUGUSTA UTILITIES DEPARTMENT
452 WALKER STREET, SUITE 200
AUGUSTA, GA 30901

